



- NOTES:**
1. OPEN CUT INSTALLATIONS WILL REQUIRE 12 GAUGE COPPER WIRE.
 2. TRENCHLESS INSTALLATIONS WILL REQUIRE 10 GAUGE STAINLESS STEEL WIRE.
 3. CONTRACTOR SHALL INSTALL DUMMY VALVE BOXES AT INTERVALS NO GREATER THAN 1000 FEET, INCLUDING ONE AT THE PUMP STATION AND ONE AT THE DISCHARGE POINT.
 4. THE WIRE AND TAPE SHALL MEET THE REQUIREMENTS OF N.C.S.D. (NORTH CHARLESTON SEWER DISTRICT) MINIMUM STANDARDS

TRACER WIRE AND MAGNETIC TAPE FOR FORCE MAINS

NOT TO SCALE

NORTH CHARLESTON SEWER DISTRICT	
7255 STALL ROAD, NORTH CHARLESTON, SC 29406 PH: (843) 764-3072 FAX: (843) 764-2555	
N.C.S.D. STANDARD DETAILS	
TRACER WIRE AND MAG. TAPE F/FM'S	
REV. DATE: 3-2-2011	DWG#: FM-002