



↳ DROP INVERT MAY COME IN ON TOP OF INVERT SHOULDER. HOWEVER A CHANNEL TO DIRECT THE FLOW TOWARD THE OUTLET PIPE SHALL BE FORMED AROUND THE BEND.

STANDARD INSIDE DROP MANHOLE DETAIL
 NOT TO SCALE

NORTH CHARLESTON SEWER DISTRICT	
7255 STALL ROAD, NORTH CHARLESTON, SC 29406 PH: (843) 764-3072 FAX: (843) 764-2655	
NCS.D. STANDARD DETAILS	
STANDARD INSIDE DROP MANHOLE	
REV. DATE: 3-2-2011	DWG#: GS-003